ARB PM2.5 Filter Processing and Validation

A Lab and Field Perspective

Ali Adams

PM2.5 Lab Analyst, Inorganic Lab Section

Joe Guerrero

Manager, Air Monitoring - North

Monitoring and Laboratory Division California Air Resources Board

Common Goal

- We are in it together
- Change is hard
- Communication is KEY





- Motivation
- What's in it for me?



Northern Laboratory Branch PM2.5 FRM, Coarse, and SASS Programs

- 46 Sites Total (FRM, Coarse, SASS)
 - BAAQMD Lab Support
 - ARB Research Division

- 6,000 samples processed per year
 - Pre- and Post- weights > 12,000 per year



- SOPs
- QAPPs
- Technical Bulletins
- EPA QA Handbook for Air Pollution Measurement Systems, Volume II
- EPA Quality Assurance Guidance Document 2.12



- EPA QA Handbook for Air Pollution Measurement Systems, Volume II
 - Validation Template (Lab and Field)
 - Critical Criteria
 - Operational Evaluations
 - Systematic Criteria

Lab Critical Criteria

| 1) Criteria (PM2.5 LC) | 2) Frequency | 3) Acceptable Range | Information /Action | |
|--|--------------------------------|--|---|--|
| CRITICAL CRITERIA- PM _{2.5} Filter Based Local Conditions | | | | |
| Post-sampling Weighing | all filters | ≤10 days from sample end date if shipped at ambient temp, or ≤30 days if shipped below avg ambient (or 4° C or below for avg sampling temps < 4° C) from sample end date | 1, 2 and 3) 40 CFR Part 50 App L Sec 8.3.6 Sampled filters must be protected from exposure to temperatures above 25C from sample retrieval to conditioning 40 CFR part 50 Appendix L Sec 10.13. See technical note on holding time requirements at: https://www3.epa.gov/ttn/amtic/pmpolgud.html | |
| Filter Visual Defect Check (unexposed) | all filters | Correct type & size and for pinholes, particles or imperfections | 1, 2 and 3) 40 CFR Part 50, App. L Sec 10.2 | |
| Filter Conditioning Environment | | | | |
| Equilibration | all filters | 24 hours minimum | 1, 2 and 3) 40 CFR Part 50, App. L Sec 8.2.5 | |
| Temp. Range | all filters | 24-hr mean 20.0-23.0° C | 1, 2 and 3) 40 CFR Part 50, App. L Sec 8.2.1 | |
| Temp.Control | all filters | < 2.1° C SD* over 24 hr | 1, 2 and 3) 40 CFR Part 50, App. L Sec 8.2.2 | |
| Humidity Range | all filters | 24-hr mean 30.0% - 40.0% RH or Within ±5.0 % sampling RH but ≥ 20.0%RH | 1, 2 and 3) 40 CFR Part 50, App. L Sec 8.2.3 | |
| Humidity Control | all filters | < 5.1 % SD* over 24 hr. | 1, 2 and 3) 40 CFR Part 50, App. L Sec 8.2.4 | |
| Pre/post Sampling RH | all filters | difference in 24-hr means < ± 5.1% RH | 1, 2 and 3) 40 CFR Part 50, App. L Sec 8.3.3 | |
| Balance | all filters | located in filter conditioning environment | 1, 2 and 3) 40 CFR Part 50, App. L Sec 8.3.2 | |
| Microbalance Auto-Calibration | Prior to each weighing session | Manufacturer's specification | 1) 40 CFR Part 50, App. L, Sec 8.1 2) 40 CFR Part 50, App. L, Sec 8.1 and Method 2.12 Sec. 10.6 3) NA | |

https://www3.epa.gov/ttn/amtic/files/ambient/pm25/qa/PM2.5_Val_Template_4_27_16.pdf

Lab Critical Criteria

- 24 Hours Balance Room "In"
 - 20 − 23 degrees C
 - 30% 40% Relative Humidity
- 24 Hours Filter Equilibration
- Filters weighed within 30 days
 - Ship filters below 4 degrees C
 - IF shipped above average ambient temp.
 samples must be weighed within 10 days.

Sample 0

Filter is Sampled

Ideal Situation

Sample <7.4 Days

Filter is Retrieved within 7.4 Days

Sample 5 Days

Filter is Shipped to Lab in 5 Days

Filter Equilibrates 24 Hours

Sample I Day

Filter Weighed the next Day

Sample 13 Days Old



Sample 0

Filter is Sampled

Unfortunate Situation

Sample <7.4 Days

Filter is Retrieved within 7.4 Days

Sample 17 Days Filter is Shipped to Lab in 17


Days

(UPS Delay)

Filter Equilibrates 72 Hours (Balance Room "Out")

Sample 3 Days

Filter Weighed After Thanksgiving weekend Holiday (4 more days)



Is It Valid?

- What info do we have from the Field?
- Does it meet the Critical Criteria?
 - Balance Room Requirements
 - Holding time Requirements
- Is there filter damage?
 - Dent, cut, fingerprint, contamination, pinhole...



- 12 Months
 - Cut/Dent/Torn/Damaged (60)
 - Pinhole(s) (32)
 - Contamination (20)

Statistics Continued

- I2 Months
 - Sample Duration <23 Hours OR >25 Hours (24)
 - Non-Midnight start time (24)
 - Retrieval >7.4 Days (14)
 - Samples not weighed within 30 Days (10)

~250 Invalid Samples Total



- Make-Ups (Except Daily sites)
 - Before next scheduled run OR
 - Exactly one week after missed/invalid run
- Send samples back to the lab ASAP
- Lab Communication

Invalid Samples Impacts


Federal Design Values

Meeting completeness criteria and required averages to reach attainment.



Sample Handling

- Chain-of-custody completeness.
 - Is it Valid?
 - Is it complete?
 - Does it make sense?
 - Are all the pieces there?



Take Out the Guesswork



Sample Handling Continued

- Noting unusual conditions on the Chainof-Custody (CoC)
 - Rain, wind
 - Fires, construction, fireworks
 - Leak checks and audits
 - Sampler issues
 - Power Outages

Sample Handling



• Submit all the pieces to the puzzle.



Positive Feedback

Synergy - the bonus that is achieved when things work together harmoniously.

-Mark Twain



Contact Info

Ali Adams

Alicia.adams@arb.ca.gov (916) 323-0668

Nial Maloney

Nial.maloney@arb.ca.gov

Sample Handling

Sample.handling@arb.ca.gov (916) 327-3447

ARB - Field Staff Responsibilities

Joe Guerrero *Manager, Air Monitoring - North*



Field Staff "Authorities"

- Invalidate samples based on field criteria before sending to lab
 - Lab staff will not invalidate field criteria
 - Document on Field Report/CoC
- Request Make-ups from Lab
 - Indicate on Field Report/CoC that sample is make-up
 - Know Make-up "Rules"

Field Guiding Documents

SOPs

Technical Bulletins

 EPA QA Handbook for Air Pollution Measurement Systems, Volume II

Document Properly

- Include appropriate information on the form
- Error on the side of including more information

 Write clearly. Blue or black ink only. No pencil. No white out. Strike out and initial changes.

Field Critical Criteria

| 1) Criteria (PM2.5 LC) | 2) Frequency | 3) Acceptable Range | Information /Action | |
|--|--|--|---|--|
| CRITICAL CRITERIA- PM2.5 Filter Based Local Conditions | | | | |
| Field Activities | | | | |
| Sampler/Monitor | NA | Meets requirements listed in FRM/FEM/ARM designation | 1) 40 CFR Part 58 App C Section 2.1 2) NA 3) 40 CFR Part 53 & FRM/FEM method list | |
| Pre-sampling | all filters | < 30 days before sampling | 1,2 and 3) 40 CFR Part 50, App.L Sec 8.3.5 | |
| Sample Recovery | all filters | < 7 days 9 hours from sample end date | 1,2 and 3) 40 CFR Part 50, App. L 10.10 | |
| Sampling Period (including multiple power failures) | all filters | 1380-1500 minutes, or if value < 1380 and exceedance of NAAQS ^{1/} midnight to midnight local standard time | 1, 2 and 3) 40 CFR Part 50 App L Sec 3.3 and 40 CFR Part 50 App N section 1 for the midnight to midnight local standard time requirement See details if less than 1380 min sampled | |
| Sampling Instrument | | | _ | |
| Average Flow Rate | every 24 hours of op | average within 5% of 16.67 liters/minute | 1, 2 and 3) Part 50 App L Sec 7.4.3.1 | |
| Variability in Flow Rate | every 24 hours of op | CV ≤ 2% | 1, 2 and 3) 40 CFR Part 50, App .L Sec 7.4.3.2 | |
| One-point Flow Rate Verification | every 30 days | < <u>±</u> 4.1% of transfer standard < <u>±</u> 5.1% of flow rate design value | 1, 2 and 3) 40 CFR Part 50, App .L, Sec 9.2.5 and 7.4.3.1 and 40 CFR Part 58, Appendix A Sec 3.2.1 | |
| Design Flow Rate Adjustment | After multi-point calibration or verification | < ± 2.1% of design flow rate | 1,2 and 3) 40 CFR Part 50, App. L, Sec 9.2.6 | |
| Individual Flow Rates | every 24 hours of op | no flow rate excursions $> \pm 5\%$ for > 5 min. $\frac{1}{2}$ | 1, 2 and 3) 40 CFR Part 50, App. L Sec 7.4.3.1 | |
| Filter Temp Sensor | every 24 hours of op | no excursions of $> 5^{\circ}$ C lasting longer than 30 min $\underline{1}$ | 1, 2 and 3) 40 CFR Part 50, App. L Sec 7.4.11.4 | |
| External Leak Check | Before each flow rate verification/calibration and before and after PM _{2.5} separator maintenance | < 80.1 mL/min (see comment #1) | 1) <u>40 CFR Part 50 App L</u> , Sec 7.4.6.1 2) 40 CFR Part 50 App L Sect 9.2.3 and Method 2-12 Section 7.4.3 3) 40 CFR Part 50, App. L, Sec 7.4.6.1 | |
| Internal Leak Check | If failure of external leak check | < 80.1 mL/min | 1) 40 CFR Part 50, App. L, Sec 7.4.6.2 2) Method 2-12 7.4.4 3) 40 CFR Part 50, App. L, Sec 7.4.6.2 | |

https://www3.epa.gov/ttn/amtic/files/ambient/pm25/qa/PM2.5_Val_Template_4_27_16.pdf

Field Criteria - Holding Times

 Filters sampled more than 30 days from their pre-weight date — Invalid

Samples left on sampler >7.4 days –
 Invalid

Return the samples to the lab promptly

Field Criteria - Sample Period

- Non-midnight Start Times Invalid
 - Midnight to Midnight Valid
- Runs 24 Hours + I are valid
 - One exception for runs between 18 and 23 hours – may be valid. Run a make-up in this situation.

Field Criteria - Flow

Average Flow Rate: within 5% of 16.67
 liters/min - Valid

Variability in Flow Rate: CV < 2% - Valid

Field Criteria – Damaged Filters

 Make sure the piston is in the correct position



Summary

- Use appropriate reference documentation
- Adhere to proper holding time requirements
- Make sure sample runs for the sampling duration
- Verify flow criteria met
- Be careful handling the filters and limit damage



- Joe Guerrero
 - · (916) 324-7591
 - joe.guerrero@arb.ca.gov